

COILING THERMAL DOOR—MODEL T33PS

08330/ATL
Buyline 0371

SPECIFICATIONS

PART 1 GENERAL

1.01 Section Includes

A. Type: Insulated Coiling Service Doors are to be Atlas Door™ Model T33PS as manufactured by Ctopay Building Products Company, Inc.

B. Operation: To be waist high crank hoist using gears and removable hand crank.

C. Mounting: To be interior face mounted in a prepared opening.

1.02 Related Work

A. Opening preparation, miscellaneous or structural steel, access panels, finish or field painting are in the scope of the work of other sections or trades.

B. Submit manufacturer's product data and installation instructions for each type of coiling door. Include both published data and any specific data prepared for this project.

1.03 Single-Source Responsibility

A. Provide doors, guides, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

PART 2 PRODUCT

2.01 Curtain

A. Slats: Assembled of interlocking galvanized steel slats front and back cold roll-formed. Slats to be Type T3, no less than 2½" (66.68 mm) high.

B. Insulation: Polyurethane foam-injected and to fill all voids providing continuous insulation protection the full height of the slat. Insulation is to be self-bonding to the two interior galvanized steel surfaces. U-Value = 0.16 (0.91 W/m² °K), R-Value = 6.25.

C. Endlocks: Each end of alternate slats to be fitted with endlocks to act as a wearing surface in the guides and to maintain slat alignment.

D. Windload: Door construction designed to satisfy windload of 20 PSF (0.96 kPa) or 87 M.P.H. (140 KPH).

E. Gauge: Thickness of slat material to be as required by width of opening and windloading conditions.

F. Galvanizing: Zinc-coated in accordance with ASTM A653.

G. Bottom Bar: Curtain to be reinforced with a bottom bar consisting of two steel angles.

H. Weather Seal: Provide interwoven neoprene astragal at the bottom bar to act as a weather seal at the floor.

2.02 Spring Counterbalance

A. Counterbalance: Housed in a steel pipe of diameter and wall thickness to restrict maximum deflection to .03" per foot (2.5 mm/m) of door width.

B. Springs: To be helical torsion type designed to include an overload factor of 25% and for optimum ease of operation. Springs are to be grease-packed and are to be mounted on a cold rolled steel inner shaft.

C. Spring Tension: Adjustable from outside of end bracket plates.

D. Ball Bearing: Sealed, to minimize wear of pipe shaft rotation around inner shaft.

2.03 Bracket Plates

A. Bracket Plates: Carrying pipe counterbalancing shaft are to be no less than ½" (6.35 mm) thickness and to house ends of door coil. Shape of plates to be square.

B. Drive End Bracket Plate: Fitted with a sealed ball bearing.

2.04 Guide and Wall Angle Assembly

A. Guides/Wall Angles: Structural steel angles of ½" (4.76 mm) minimum thickness.

B. Depth of Guide: To provide adequate slat penetration to satisfy specified windloading.

C. Guide Weather Seal: Furnish guide weatherstripping to seal against T3 slat.

2.05 Hoods

A. Hoods: To house coil are to be fabricated of #24 U.S. Gauge galvanized steel.

B. Reinforcing: To be laterally reinforced to prevent sag.

C. Intermediate Hood Supports: Furnish where door width exceeds 16'-0" (4877 mm).

D. Hood Baffle: Furnish neoprene hood baffle in hood to prevent air infiltration.

2.06 Locking

A. Locking Disc: On crank box of crank hoist suitable for padlocking (padlock by others).

2.07 Finish

A. Galvanized Surfaces: Slats and hood (etc.) galvanized. Baked-on gray or tan coat of epoxy-modified polyester on slats and hood. Shop coat of rust-inhibiting metallic primer on all remaining ungalvanized surfaces, except bearings.

B. Ungalvanized Surfaces: Shall consist of a shop coat of rust-inhibiting metallic primer (gray) (brown) on exposed ferrous surfaces, except bearings.

PART 3 EXECUTION

3.01 Examination

A. Verify that dimensions are correct and project conditions are suitable for installation. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.02 Installation

A. Installation: To be by Atlas Door authorized representative and in accordance with Atlas Door standards and instructions.

B. Submit manufacturer's product data and installation instructions for each type of coiling door. Include both published data and any specific data prepared for this project.

Note to Specifiers... Please see end of this section for frequently specified Optional Features.

Opening Height	Without Windlocks				With Windlocks				Opening Width	Without Windlocks		With Windlocks	
	'D'	'G'	'E'	'F'	'D'	'G'	'E'	'F'		'A'	'B'	'A'	'B'
to 9'-1" (2769 mm)	17"	17½"	3"	3½"	18"	19½"	3½"	4½"	to 12'-4½" (3781 mm)	9½"	13½"	9"	13"
9'-1½" to 11'-1" (2772 mm) (3378 mm)	18"	18½"	3"	3½"	19"	19½"	3½"	4½"	(215.3 mm)(317.5 mm)	(228.6 mm)(330.2 mm)	(228.6 mm)(330.2 mm)	(228.6 mm)(330.2 mm)	
11'-1½" to 13'-1" (3381 mm)(3988 mm)	18"	19½"	3"	3½"	20"	20½"	3½"	4½"	12'-5" to 22'-4½" (3788 mm) (8429 mm)	9"	13"	9"	13"
13'-1½" to 15'-1" (3991 mm) (4597 mm)	20"	20½"	3½"	4½"	21"	21½"	4½"	5½"	(228.6 mm)(330.3 mm)	(228.6 mm)(330.3 mm)	(228.6 mm)(330.2 mm)	(228.6 mm)(330.2 mm)	
15'-1½" to 17'-1" (4601 mm) (5207 mm)	21"	21½"	3½"	4½"	22"	22½"	4½"	5½"	22'-5" to 24'-4½" (6833 mm) (7439 mm)	Not Applicable	9½"	13½"	(241.3 mm)(342.9 mm)
17'-1½" to 20'-1" (5210 mm) (6121 mm)	23"	23½"	3½"	4½"	24"	24½"	4½"	5½"	over 24'-4½" (7439 mm)	Not Applicable	Consult Technical Services	Consult Technical Services	
over 20'-1" (6121 mm)	Consult Technical Services				Consult Technical Services								

COILING THERMAL DOOR—MODEL T33*


08330/ATL
Buyline 0371

- Waist high crank operated
- Interior face mounted
- Fully weatherstripped
- R-Value = 6.25
- U-Value = 0.16
- (U = 0.91 W/m² °K)

*Suffix letters indicate material and/or finish of curtain.

For alternate material or finish of curtain see Optional Features.

- GS Galvanized, without baked-on finish coat
- PS Galvanized with baked-on finish coat
- MA Mill finish aluminum
- AA Clear anodized aluminum
- DA Bronze aluminum
- ST Stainless steel




3" (76.2 mm) is dimension of top hood bead. Where headroom is limited, 3" (76.2 mm) requirement can be eliminated by turning bead down.

Windlocks are standard on doors over 22'-4 1/8" (6829 mm) wide and optional for doors under 22'-4 1/8" (6829 mm) wide.

Where clearances are critical, dimensions shown can be reduced. Consult Technical Services.

GUIDE DETAILS



atlas door™